

PUBLIC HEALTH ENGINEERING DEPARTMENT

Regional Water Testing Laboratory

Month-April 2026

District Name : Muzaffarpur

Sl. No.	Block	Panchayat	Village	Location of Source	pH	Turb.	EC	TDS	TH	Ca	Mg	Cl	Alk	Fe	So ₄	Remarks
1	Minapur	Maksudpur	Maksudpur	Momastic English School	7.14	1.6	498	324	182	40	19.9	29.2	156	0.3	10	
Acceptable Limit (IS 10500-2012)					6.5-8.5	1 NTU	–	500 mg/l	200 mg/l	75 mg/l	30 mg/l	250 mg/l	200 mg/l	1.0 mg/l	200 mg/l	
Permissible Limit in absence of alternate source (IS 10500-2012)					NR	5 NTU	–	2000 mg/l	600 mg/l	200 mg/l	100 mg/l	1000 mg/l	600 mg/l	NR	400 mg/l	


CHEMIST
 R.W.T.L. MUZAFFARPUR
 15/04/26


ARO
 RWTL, Muzaffarpur
 15.04.26